



REQUESTS FOR BIDS

RFB 26BCP03B

Rivers Crossing Subdivision Asphalt Replacement Project

March 30, 2026

**ADDENDUM #1**

Notice to Respondents:

This addendum will be considered a part of Bastrop County's Request for Bids for Rivers Crossing Subdivision Asphalt Replacement Project. Where provisions of this addendum differ from those of the original Requests for Bids, this addendum will govern.

ACKNOWLEDGED

\_\_\_\_\_  
Printed Name of Respondent

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date

RETURN ONE COPY SIGNED COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE WITH YOUR SEALED BID. FAILURE TO DO SO, MAY AUTOMATICALLY DISQUALIFY YOUR RESPONSE FROM CONSIDERATION FOR AWARD.

## ITEMS FOR ADDENDUM #1:

Bastrop County held a pre-bid meeting at the project site on March 27, 2026, and the following questions were presented by attendees. Bastrop County is providing all questions and answers to all interested contractors.

**All bids must be mailed to or hand delivered to 1041 Lovers Lane, Bastrop, Texas 78602. All bids must be received by Bastrop County no later than April 9, 2026, at 2:00PM.**

**Q. Will the HOA be turning the Sprinkler System off for this project?**

**A. Yes, Bastrop County will coordinate with the HOA to ensure the water sprinkler system is not active during construction.**

---

**Q. What are the working hours for construction?**

**A. There are no time constraints.**

---

**Q. Does Bastrop County allow RAP (recycled asphalt pavement) in the mix?**

**A. Yes, up to TxDot's standards.**

---

**Q. Where do the spoils for the project need to be left?**

**A. Bastrop County has a designated area where the spoils can be left. The location is within a mile of the project site. Awarded contractor will coordinate spoil drop off with Bastrop County Road and Bridge Precinct Commissioner and Foreman.**

---

**Q. Is a bid bond required for this project?**

**A. No, a bid bond is not required. However, as listed in the requests for bids section II. *CONTRACT TERMS AND CONDITIONS, subsection N - Payment and Performance Bonds: Payment and Performance bonds shall be required and issued for this contract should the total bid price reach the State of Texas threshold for public works projects.***

---

**Q. How much concrete is covered under the current cold mix?**

**A. There are 2 large stretches of concrete, however the quantity or size is unknown.**

---

**Q. Does the concrete need to be removed?**

**A. No, the concrete is deeper than the requested scope of work is requiring the awarded contractor to dig out. Awarded contractor should not have any issues with these concrete sections. Should the concrete become an issue after starting this project a solution will be agreed upon by Bastrop County and the awarded contractor, and a change order will be issued if required. This bid should NOT reflect the presence of concrete under the existing roadway.**